

April 30, 2007

Mr. Jim Keene Keene Building Products P.O. Box 241353 Mayfield Heights, OH 44124

Dear Jim,

Subject: Project No. 3120037 – Letter Report

Intertek Testing Services NA Ltd. has conducted an evaluation for Keene Building Products on your product, Keene Driwall 10 mm to determine compliance with the 2005 National Building Code of Canada (NBC), Section 9.27.2.2, Item 1b and 2006 British Columbia Building Code (BCBC), Section 9.27.2.2, Item 1b. The tests were conducted in accordance with recognized ASTM test methods. The measured physical dimensions together with the relevant requirements specified in NBC and BCBC are shown in Table 1 below:

Table 1. Keene Driwall 10 mm Test Results			
Physical Property	Test Result	Requirement	Pass/Fail
Product Thickness, mm	10.9	10 min.	Pass
Cross-sectional Area, % open	94	80 min.	Pass

Based on the information detailed in Table 1, the Keene Driwall 10 mm product has met the physical requirements of Section 9.27.2.2, Item 1b of the 2005 National Building Code of Canada and 2006 British Columbia Building Code.

If you require further assistance, do not hesitate to contact the undersigned directly at (604) 520-3321.

Sincerely,

INTERTEK TESTING SERVICES NA LTD.





Craig Lawson, NZCE (Mech.) Manager, Construction Products

crl/ahvs



All services undertaken are subject to the following general policy: This report is for the exclusive use of Intertek Testing Services NA Ltd.'s (Intertek's) client and is provided pursuant to the agreement between Intertek and its client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the client is authorized to copy of distribute this report and then only in its entirety. Intertek must first approve any use of the Intertek name or one of its marks for the sale or advertisement of the testing materials, product or service in writing. The observations and test results in the report are relevant only to the sample tested. This report by itself does not imply that the material, product or service is or has ever been under Intertek's certification program.